



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
RENEWAL of NO OBJECTION CERTIFICATE**



Ack. No.: 199460002019 Issue Date : 11/09/2019
 NOC: 0007100/RENEWAL/Jangaon/2019
 NOC TYPE: RENEWAL*

Valid Upto: 10-09-2024

Applicant Details: VIJAYA BHASKAR A,9885111871,Sage International school,Syno.196/2,3,4,5 &196/7 situated at Yeshwanthapur(v)Jangaon(M)Jangaon(Dist)

Building for which NOC issued: sage International school,Sage International school,Syno.196/2,3,4,5 &196/7 situated at Yeshwanthapur(v)Jangaon(M)Jangaon(Dist)/-Yeswanthapur/Jangaon/Jangaon

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:		No	
Plot Area (Sq. Mtrs):	8092.00	Height (Metres):	9.00
Open Spaces (Metres):	North: 6.00	South: 6.00	East: (F) 6.00 West: 6.00
No. of Floors: 0 Cellars, 0 Stilts, 1 Ground, 2 Floors, 0 Terrace		Occupancy Type:	EDUCATIONAL B-1 Schools up to senior secondary level
Total Built-up Area (Sq.Mtrs):	1417.76	Staircases:	No. of Staircases Required/Proposed: 2
Fees Paid (₹):	20000		Aggregate Width Required/Proposed (Metres): 2.22

Fighting Installations Provided as per Table 23, Part-IV of NBC, 2005:

Fire Extinguisher:	12	First Aid Hose Reel:	3	Wet Riser:	0
Down Comer:	1	Yard Hydrant:	0	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Litres):	10000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Litres):	0		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm2 at Terrace Level	Type	Quantity	(Capacity in Litres/min)
	Electrical	0	0
	Diesel	0	0
	Jockey	0	0

Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm2	(Capacity in Litres/min)
	450

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"
 '* For details and conditions of Renewal No Objection Certificate for Occupancy, refer overleaf'.